

Use of MSA (Measurement statistical analysis) for evaluation of measuring systems for quality control of an automatic production line

Valentin Tsenev
College of Energy and Electronics
TU Sofia
Botevgrad, Bulgaria
vtsenev@tu-sofia.bg

Uliana Georgieva Asenova
Faculty of Engineering and Pedagogy
TU Sofia
Sofia, Bulgaria
asenova_uliana_94@abv.bg

Abstract—The MSA (Measurement statistical analysis) method was used to evaluate the measuring systems for quality assessment in the production of connectors (electromechanics) for the automotive industry on an automatic production line. Based on the collected data, an analysis of the capabilities of the measuring system was performed using QSTATLAB. A conclusion was made on the basis of the obtained results with conclusions regarding the admissibility of the process and its improvement.

Keywords— *quality, measurement, control, repeatability and reproducibility*

I. INTRODUCTION

In fast automatic production processes, secure measuring and control modules are used, which must be properly set up and verified. A modern method for evaluation and verification of such modules is MSA [1], which examines the impact of equipment, method, materials, operator and environment [2] and ensures their proper use. Many software products [3, 4] are used for the application of MSA, in which there is a built-in module for MSA assessment. The evaluation parameter is R&R, which is a measure of the repeatability and reproducibility of the measuring system. Based on statistics and correlations, the limits of R&D [5] are determined, at which measuring systems can be used or need to be improved.

The procedure for conducting an MSA includes the following steps:

- 1) Sampling of controlled objects (volume $n \Rightarrow 10$);
- 2) Measurement of individual objects by several controllers several times;
- 3) Processing of the obtained results and determination of the components of the full variation;
- 4) Comparison of the result with the admissible values and assessment of the measuring system.

The main components of the complete variation of the measuring system are:

- Deviation;
- Repeatability;
- Reproducibility;
- Stability;
- Linearity.

Deviations of these components are caused by various problems - wear standard or error in the standard, worn components of the device, poorly designed device or incorrect application, wrong measuring method or calculation, incorrect calibration of the tool, environmental impact, the tool is used inappropriately or incorrectly by other operators. The obtained data are then suitable for application and development of new processes that need to be tested.

II. EXPERIMENTS

The test product is shown on fig. 1.




Fig.1. g8680x connector

Automatic production is done in several steps:

- Injection molded plastic body;
- Automatic assembly of metal terminals (CuSn6) in the plastic body;
- Automatic 100% product control for functionality-critical features;
- Automatic packaging in roll packaging (strap with separate slots for each product).

In fig. 2. the automatic production line for connectors assembly with the control stations is shown.




Fig. 2. The studied automatic production line

The critical controlled parameters of the g8680x connector product are rendered on fig. 3.




Fig. 3. Critical dimensions

The control stations are:

- 24 V – control for missing terminal, short or long terminal on the interface side and distorted terminal interface or PCB side – fig.3.(1),(3), (5), (6);
- pattern board - distorted terminal on the PCB side - fig.3.(2), (5);
- pattern interface - distorted output on the interface side – fig.3.(3), (4);
- 1000V – control for short circuit from inclusions and contaminants using a tester AC/DC Withstand Voltage / IR / GB.

Next is a packaging station, which is also a stamp for a suitable product. Non-compliant products are automatically separated in a special red box.

The control stations work on the principle of using patterns and electrical measurements for the presence or absence of contact and circuit.

III. RESULTS

The results and analysis were made for each type of control using the MSA method by collecting and processing data for analysis of the measuring system. For this purpose, reference samples were used, which were pre-measured to the appropriate dimensions with a precision measuring

instrument model CNC Quick Scope QS-250 - Mitutoyo. The results were obtained using the software product QSTATLAB, which has a built-in MSA method.

A. HEIGHT OF THE TERMINALS OF THE INTERFACE

a) The height of the contact terminals is checked by measuring a size of 7.6 ± 0.2 mm, which is shown in fig. 3 (1). The size tolerances are determined according to ISO 2768-m. This defect will result in improper connector assembly during the next manufacturing operation. The required reference standard samples of this station are OK and NOK with different values close to the limit 7.4mm / 7.8mm. Tables 1, 2 and 3 show the measurement of reference samples, with the help of which an R&R analysis is made by qualitative characteristics - check for the presence of short or long leads.

TABLE I.

OK sample		
Pin1 Int 2	7.785	0.185
Pin3 Int 2	7.528	-0.072
Pin1 Int 1	7.616	0.016
Pin2 Int 1	7.547	-0.053
Pin5 Int 1	7.54	-0.06
Pin6 Int 1	7.547	-0.053
Pin7 Int 1	7.514	-0.086
Pin8 Int 1	7.487	-0.113
Pin9 Int 1	7.509	-0.091

TABLE 2.

NOK sample – short leads		
Pin1 Int 2	7.601	0.001
Pin3 Int 2	7.542	-0.058
Pin1 Int 1	7.506	-0.094
Pin2 Int 1	7.479	-0.121
Pin5 Int 1	7.37	-0.23
Pin6 Int 1	7.427	-0.173
Pin7 Int 1	7.575	-0.025
Pin8 Int 1	7.425	-0.175
Pin9 Int 1	7.435	-0.165

TABLE 3.

NOK sample – long leads		
Pin1 Int 2	7.773	0.173
Pin3 Int 2	7.536	-0.064
Pin1 Int 1	7.613	0.013
Pin2 Int 1	7.849	0.249
Pin5 Int 1	7.849	0.249
Pin6 Int 1	7.853	0.253
Pin7 Int 1	7.673	0.073
Pin8 Int 1	7.473	-0.127
Pin9 Int 1	7.489	-0.111

The R&R analysis was performed by checking with 20 samples - suitable and unsuitable for the respective indicator. The "Sign" column records the result to be given by the relevant sample during the inspection. The samples are placed at the station five times and a result is reported. The data are a total of 100. The result is shown in Table 4.

TABLE 4.

Attribute Gage R & R/Gage R & R по атрибути							
Report / Доклад		Date/Дата					
Attribute Legend/Легенда		Name/Име					
1. pass/съответ. - Yes/Да		Product/Продукт					
2. fail/несъответ. - No/Не		Process/Процес					
Known Population		Y/N					
Sample#	Attribute	Trial 1	Trial 2	Trial 3	Trial 4	Trial 5	Agree
Мостра No	Признак						Съответен
1	Yes	Yes	Yes	Yes	Yes	Yes	Yes
2	Yes	Yes	Yes	Yes	Yes	Yes	Yes
3	No	No	No	No	No	No	Yes
4	No	No	No	No	No	No	Yes
5	No	No	No	No	No	No	Yes
6	Yes	Yes	Yes	Yes	Yes	Yes	Yes
7	Yes	Yes	Yes	Yes	Yes	Yes	Yes
8	No	No	No	No	No	No	Yes
9	No	No	No	No	No	No	Yes
10	Yes	Yes	Yes	Yes	Yes	Yes	Yes
11	Yes	Yes	Yes	Yes	Yes	Yes	Yes
12	No	No	No	No	No	No	Yes
13	Yes	Yes	Yes	Yes	Yes	Yes	Yes
14	No	No	No	No	No	No	Yes
15	Yes	Yes	Yes	Yes	Yes	Yes	Yes
16	No	No	No	No	No	No	Yes
17	Yes	Yes	Yes	Yes	Yes	Yes	Yes
18	No	No	No	No	No	No	Yes
19	No	No	No	No	No	No	Yes
20	Yes	Yes	Yes	Yes	Yes	Yes	Yes

Note/Забелешка: Attribute Gage R&R Control for height of pins from interface side with EOL 0200188 - working station № 4 according to drawing 6468245-01/17.09.2019.
Gage R&R за атрибути е направен за проверка височината на изводите от интерфейс страната с линия 0200188- Станция № 4 по работен чертеж 6468245-01/17.09.2019.
Conclusion/Заклучение: The results are acceptable and EOL can be used in production. / Въз основа на показваните резултати линията се приема за използване в производството.

B. CURVED OUTPUT ON THE SIDE INTERFACE

The curved terminal of the interface side is checked by measuring the size 0 + 0.3 / -0mm, which is shown in fig. 3. (3), (4). Tables 5 and 6 show the measurement of reference samples, with the help of which R&R analysis is performed by qualitative features - check for the presence of curved terminals on the interface site.

TABLE 5.

cv.5/Part 1		
Отклонение по X #13.01 (±0,15)	Отклонение по Y #17.02 (±0,2)	Number pins
-0.132	0.031	Pin 1 Interface 2
-0.022	-0.005	Pin 3 Interface 2
Отклонение по X #8.07 (±0,15)	Отклонение по Y #10.01 (±0,2)	Number pins
0.143	0.063	Pin 1 Interface 1
0.001	0.002	Pin 7 Interface 1
Отклонение по X #8.01 (±0,275)	Отклонение по Y #11.05 (±0,275)	Number pins
0.071	0.280	Pin 2 Interface 1
-0.116	-0.070	Pin 5 Interface 1
-0.063	0.054	Pin 6 Interface 1
-0.093	-0.012	Pin 8 Interface 1
-0.146	-0.024	Pin 9 Interface 1

TABLE 6.

cv.1/Part 1		
Отклонение по X #13.01 (±0,15)	Отклонение по Y #17.02 (±0,2)	Number pins
-0.087	0.002	Pin 1 Interface 2
-0.034	0.042	Pin 3 Interface 2
Отклонение по X #8.07 (±0,15)	Отклонение по Y #10.01 (±0,2)	Number pins
-0.167	-0.065	Pin 1 Interface 1
0.057	0.119	Pin 7 Interface 1
Отклонение по X #8.01 (±0,275)	Отклонение по Y #11.05 (±0,275)	Number pins
-0.003	-0.233	Pin 2 Interface 1
-0.145	-0.251	Pin 5 Interface 1
-0.003	-0.331	Pin 6 Interface 1
-0.069	0.265	Pin 8 Interface 1
-0.215	0.214	Pin 9 Interface 1

In fig. 4. NOK and OK samples are shown.




Fig. 4. NOK and OK samples

The test was performed with 20 samples and the result is shown in a table 7.

TABLE 7.

Attribute Gage R & R/Gage R & R по атрибути							
Report / Доклад		Date/Дата					
Attribute Legend/Легенда		Name/Име					
1. pass/съответ. - Yes/Да		Product/Продукт					
2. fail/несъответ. - No/Не		Process/Процес					
Known Population		Y/N					
Sample#	Attribute	Trial 1	Trial 2	Trial 3	Trial 4	Trial 5	Agree
Мостра No	Признак						Съответен
1	No	No	No	No	No	No	Yes
2	No	No	No	No	No	No	Yes
3	Yes	Yes	Yes	Yes	Yes	Yes	Yes
4	No	No	No	No	No	No	Yes
5	No	No	No	No	No	No	Yes
6	Yes	Yes	Yes	Yes	Yes	Yes	Yes
7	Yes	Yes	Yes	Yes	Yes	Yes	Yes
8	No	No	No	No	No	No	Yes
9	No	No	No	No	No	No	Yes
10	Yes	Yes	Yes	Yes	Yes	Yes	Yes
11	Yes	Yes	Yes	Yes	Yes	Yes	Yes
12	No	No	No	No	No	No	Yes
13	Yes	Yes	Yes	Yes	Yes	Yes	Yes
14	No	No	No	No	No	No	Yes
15	Yes	Yes	Yes	Yes	Yes	Yes	Yes
16	No	No	No	No	No	No	Yes
17	Yes	Yes	Yes	Yes	Yes	Yes	Yes
18	Yes	Yes	Yes	Yes	Yes	Yes	Yes
19	Yes	Yes	Yes	Yes	Yes	Yes	Yes
20	No	No	No	No	No	No	Yes

Note/Забелешка: Attribute Gage R&R Control pins position from interface side with EOL 0200188 - working station № 6 according to drawings № C-208-18095-1/06.04.2018, C-208-18096-1/06.04.2018.
Gage R&R за атрибути е направен за проверка позицията на изводите от интерфейс страната на изводите от страна на платката с линия 0200188- Станция № 6 по работни чертежи № C-208-18095-1/06.04.2018, C-208-18096-1/06.04.2018.
Conclusion/Заклучение: The results are acceptable and EOL can be used in production. / Въз основа на показваните резултати линията се приема за използване в производството.

C. CURVED OUTPUT ON THE PCB SIDE

A curved terminal on the PCB side is checked by measuring a size of 0 + 0.6 / -0mm, which is shown in fig. 3.(2), (5).

Tables 7 and 8 show the measurement of reference samples, with the help of which an R&R analysis is made by qualitative features - check for the presence of curved terminals of the site for the printed circuit board.

TABLE 8

cv.2/Part 2				
Position x 2 r-r 1.02	Pins Position PCB	Отклонение по X	Отклонение по Y	Number pins
0.506	0.253	-0.080	-0.240	Pin 1 Interface 2
0.000	0.000			Pin 3 Interface 2
0.625	0.313	-0.141	-0.279	Pin 1 Interface 1
0.000	0.000			Pin 7 Interface 1
Position x 2 r-r 2.02	Pins Position PCB	Отклонение по X	Отклонение по Y	Number pins
0.397	0.199	0.185	0.072	Pin 2 Interface 1
0.439	0.219	-0.173	0.135	Pin 5 Interface 1
0.240	0.120	-0.003	-0.120	Pin 6 Interface 1
0.347	0.173	-0.059	0.163	Pin 8 Interface 1
0.425	0.213	-0.182	0.110	Pin 9 Interface 1

TABLE 9

cv.8/Part 1				
Position x 2 r-r 1.02	Pins Position PCB	Отклонение по X	Отклонение по Y	Number pins
0.513	0.257	0.167	-0.195	Pin 1 Interface 2
0.197	0.098	0.021	-0.096	Pin 3 Interface 2
0.284	0.142	0.037	-0.137	Pin 1 Interface 1
0.327	0.163	0.011	-0.163	Pin 7 Interface 1
Position x 2 r-r 2.02	Pins Position PCB	Отклонение по X	Отклонение по Y	Number pins
0.088	0.044	-0.024	-0.037	Pin 2 Interface 1
0.273	0.136	-0.117	0.070	Pin 5 Interface 1
0.596	0.298	-0.285	0.087	Pin 6 Interface 1
0.282	0.141	-0.126	-0.063	Pin 8 Interface 1
0.562	0.281	-0.244	-0.139	Pin 9 Interface 1

TABLE 11.

Attribute Gage R & R/Gage R & R по атрибути							
Report / Доклад							
		Date/Дата		23.11.2020			
Attribute Legend/Легенда		Name/Име		Юлиана Асенова			
1. pass/съответ. - Yes/Да		Product/Продукт		202-646824-00-299			
2. fail/несъответ. - No/Не		Process/Процес		Short circuit control via high voltage/ Тест високо напрежение (1000V)			
Known Population						Y/N	
Sample No	Attribute Признак	Trial 1	Trial 2	Trial 3	Trial 4	Trial 5	Agree Становище
1	No	No	No	No	No	No	Yes
2	No	No	No	No	No	No	Yes
3	Yes	Yes	Yes	Yes	Yes	Yes	Yes
4	No	No	No	No	No	No	Yes
5	No	No	No	No	No	No	Yes
6	Yes	Yes	Yes	Yes	Yes	Yes	Yes
7	Yes	Yes	Yes	Yes	Yes	Yes	Yes
8	No	No	No	No	No	No	Yes
9	No	No	No	No	No	No	Yes
10	Yes	Yes	Yes	Yes	Yes	Yes	Yes
11	Yes	Yes	Yes	Yes	Yes	Yes	Yes
12	No	No	No	No	No	No	Yes
13	Yes	Yes	Yes	Yes	Yes	Yes	Yes
14	No	No	No	No	No	No	Yes
15	Yes	Yes	Yes	Yes	Yes	Yes	Yes
16	No	No	No	No	No	No	Yes
17	Yes	Yes	Yes	Yes	Yes	Yes	Yes
18	Yes	Yes	Yes	Yes	Yes	Yes	Yes
19	Yes	Yes	Yes	Yes	Yes	Yes	Yes
20	No	No	No	No	No	No	Yes

Note/Забелешка: Attribute Gage R&R Short circuit control via high voltage with EOL 0200188 - working station № 7 according to Control Plan Number ПОК-001-MHT-228.
Gage R&R за атрибути е направен за тест високо напрежение с линия 0200188- Станция № 7, съгласно работна инструкция номер ПОК-001-MHT-228.
Conclusion/Заклучение: The results are acceptable and EOL can be used in production. / Въз основа на показаните резултати линията се приема за използване в производството.

The test was performed with 20 samples and the result is shown in a table 10.

TABLE 10.

Attribute Gage R & R/Gage R & R по атрибути							
Report / Доклад							
		Date/Дата		22.11.2020			
Attribute Legend/Легенда		Name/Име		Юлиана Асенова			
1. pass/съответ. - Yes/Да		Product/Продукт		202-646824-00-299			
2. fail/несъответ. - No/Не		Process/Процес		Check pins position from PCB side / Проверка позицията на изводите от страна на платката			
Known Population						Y/N	
Sample No	Attribute Признак	Trial 1	Trial 2	Trial 3	Trial 4	Trial 5	Agree Становище
1	Yes	Yes	Yes	Yes	Yes	Yes	Yes
2	Yes	Yes	Yes	Yes	Yes	Yes	Yes
3	No	No	No	No	No	No	Yes
4	No	No	No	No	No	No	Yes
5	No	No	No	No	No	No	Yes
6	Yes	Yes	Yes	Yes	Yes	Yes	Yes
7	Yes	Yes	Yes	Yes	Yes	Yes	Yes
8	No	No	No	No	No	No	Yes
9	No	No	No	No	No	No	Yes
10	Yes	Yes	Yes	Yes	Yes	Yes	Yes
11	Yes	Yes	Yes	Yes	Yes	Yes	Yes
12	No	No	No	No	No	No	Yes
13	Yes	Yes	Yes	Yes	Yes	Yes	Yes
14	No	No	No	No	No	No	Yes
15	Yes	Yes	Yes	Yes	Yes	Yes	Yes
16	No	No	No	No	No	No	Yes
17	Yes	Yes	Yes	Yes	Yes	Yes	Yes
18	No	No	No	No	No	No	Yes
19	No	No	No	No	No	No	Yes
20	Yes	Yes	Yes	Yes	Yes	Yes	Yes

Note/Забелешка: Attribute Gage R&R Control pins position from PCB side with EOL 0200188 - working station № 5 according to drawings 6468245-01/17.09.2019.
Gage R&R за атрибути е направен за проверка позицията на изводите от страна на платката с линия 0200188- Станция № 5 по работни чертежи 6468245-01/17.09.2019.
Conclusion/Заклучение: The results are acceptable and EOL can be used in production. / Въз основа на показаните резултати линията се приема за използване в производството.

D. 1000 V LEAK TEST

The inspection was performed with 20 samples, which are shown on fig. 5.



Fig. 5. Leak check samples at 1000 V

Table 11. shows R&R analysis by qualitative characteristics - high voltage test - 1000V.

IV. CONCLUSION

After many measurements and analysis of the obtained results, we can assume that the described method is a necessary tool for validation, as well as a method for localization and proof of incorrect control.

In the course of the research work, many improvements were made on the basis of the statistical information obtained and analyzed from the experiments. By correlation, the control parameters were set with optimal limits, which allowed real-time control of the product and a significant reduction in re-testing.

By preparing FMEA (risk analysis) can be organized predictive maintenance of samples, which will significantly reduce the risk of using worn-out samples and will improve their functionality, will increase their reliability.

The tested procedure and equipment can also be used for measurements of samples from experimental production and processes.

ACKNOWLEDGMENT

The authors is grateful to MIKROAK Ltd for the resources they have provided in conducting the experimental work.

The authors would like to thank the Research and Development Sector at the Technical University of Sofia for the financial support.

REFERENCES

- [1] MSA, Fourth edition, 2010.
- [2] Measurement System Variability Cause and Effect Diagram, MSA, Fourth edition, pp.17.
- [3] Minitab 17, 2016.
- [4] QSTATLAB 6, 2012.
- [5] MIKROAK MSA instruction, 2020.